

Certificate Of Analysis

Report NO: EM-2015-00584_02	Sample Description: Reservoir Water
Customer: African Water Solutions	No. of Samples: 3
Address: 15 Beryllium Road Alrode Johannesburg 1451	Sample Condition: Room Temperature
Contact: Henry Ashford	Sample Identification: Efficacy Test using Puresan Pro
Phone: 011 864 6290 Fax: 086 234 6917	Date Received: 09-Nov-2015 Date Completed: 27-Nov-2015
Order No: EFT	

			SAMPLE IDENTIFICATION		
			EM-15-02996	EM-15-02997	EM-15-02998
			Reservoir Water 1 (Nil Sanitizer - To be Added)	Reservoir Water 2 (Kill Test - Add 200ul Puresan Pro per 500ml Sample)	Reservoir Water 3 (Kill Test - Add 400ul Puresan Pro per 500ml Sample)
Analysis	Unit	Method			
Heterotrophic Plate Count	CFU/mL	MM-MIC001	405000	75	67
Faecal coliforms	CFU/100mL	MM-MIC003	110	<1	<1
Pseudomonas aeruginosa	CFU/100mL	MM-MIC006	160000	60	40
Salmonella spp. *	CFU/100ml	MM-MIC008	Present	Absent	Absent
E. coli	CFU/100mL	MM-MIC003	66	<1	<1
Total Coliforms	CFU/100mL	MM-MIC002	29000	<1	<1

This report relates only to the samples actually supplied to CSIR CONSULTING AND ANALYTICAL SERVICES. The operation unit does not accept responsibility for any matters arising from the further use of these results. This certificate shall not be reproduced, except in full, without the written approval of the Laboratory Manager. No reference may be made to the CSIR or any of its operation units or officers in advertisements or for sale or publicity purposes without the CSIR's prior approval. All work is undertaken according to the CSIR general conditions of contract. Samples may be discarded two weeks from the issue date of this certificate so please notify us within this time if you have any comments or queries about this certificate or results.

Remarks: * This is not SANAS accredited and is not included in the SANAS Schedule of accreditation for this laboratory.



M Gurtal - Technical Signatory

Date Printed
27-Nov-2015

Page 1 of 1